

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:173 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Model 4297 Polling Loop Extender Module. Unit is an accessory for use with listee's separately listed fire alarm control panels supporting polling devices. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 10 - 14 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use only with listee's separately listed electrically compatible fire alarm control units. Unit must be installed within the control panel or other listed enclosure.

07-09-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager